

DHEERU POWERGEN PVT. LTD.

1050 MW TPP at Dhanras Village, Korba District, Chhattisgarh, India
ADDENDUM TO INSTRUCTIONS TO BIDDERS

**ADDENDUM NO. 4
TO THE TENDER DOCUMENTS
FOR ENGINEERING PROCUREMENT AND CONSTRUCTION OF BTG PACKAGE**

REF. TENDER SPECIFICATION NO. TCE. 5888A-H-500-001

- 1. The following are the modifications to the General Conditions of Contract (GCC) for the Engineering Procurement and Construction (EPC) of BTG Package.**

Sr. No.	CLAUSE / SPECIFICATION No.	DESCRIPTION
1	Clause No.3.12.1 of General Conditions of Contract (GCC), Section A4, Volume –I of specifications.	<p>The first sentence of the para is modified as under:</p> <p>“Construction power would be made available by the Owner at the proposed Site either at 11 kV or at 33 kV within the plant boundary at one point and the Contractor shall make his own arrangements for further distribution and shall be responsible for the maintenance of his distribution system.”</p>
2	Clause 11.2.1 of General Conditions of Contract (GCC), Section A4, Volume-I of specifications.	<p>This clause is modified and should be read as follows:</p> <p>“The Performance Liquidated Damages payable by the Contractor to the Owner will be calculated Unit wise in case each Unit fails to meet the Performance Guarantees furnished by the Contractor in Schedule F3 of Volume –II, at the rates set forth in the following Table:</p>

DHEERU POWERGEN PVT. LTD.

1050 MW TPP at Dhanras Village, Korba District, Chhattisgarh, India ADDENDUM TO INSTRUCTIONS TO BIDDERS

PERFORMANCE PARAMETERS FOR WHICH LIQUIDATED DAMAGES (LD) WILL BE LEVIED IN RESPECT OF EACH UNIT

Sr. No.	Description	Liquidated Damages (LD) leviable in Rs. Lakhs
1.0	For every 1 kW increase in the total Auxiliary power consumption	1.80
2.0	For every 1 kcal/kwh increase in Gross weighted unit heat rate per MW	0.25
3.0	For every 1mWC increase in cooling water pressure drop across condenser per MW	0.74
4.0	For shortfall in power output for every 1kW	1.80
5.0	For every 1 TPH shortfall of steam flow at super heater outlet	37.0
6.0	For every 0.1% decrease in S.G. efficiency per MW	0.63

Bidders who have submitted Bids by the date of this Addendum shall submit either an undertaking that they accept the amended General Conditions of Contract (GCC) for the Engineering Procurement and Construction (EPC) of BTG Package as above and that their Bids shall apply *mutatis mutandis* or submit a revised Bid after collecting their original unopened Bids.

The Owner further reserves the right to modify any of the terms and conditions of the Tender Documents.